

This document must be retained for future reference.


It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation.  
All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS



IP163F - IP323F IP44 Industrial Plugs  
110V 16-32A 2P + E



Part Number	Amps	Colour and Voltage	Poles	Protection Degree	a (mm)	b (mm)	c (mm)	sw(mm)	Cable Nominal Cross Section Area
IP163F	16A	Yellow 110V	2P + E	IP44	116	55	6-15	38	1 - 2.5
IP323F	32A				145	72	10-20	50	2.5 - 6