

This document must be retained for future reference.


It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation.
All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS



IP67 Weather Proof Industrial Surface Sockets
16-32A



Part Number	Amps	Colour and Voltage	Poles	Protection Degree	a (mm)	b (mm)	c (mm)	d (mm)	e (mm)	f (mm)	g (mm)	Cable Nominal Cross Section Area
ISSW163F	16A	Yellow 110V	2P + E	IP67	82	69.5	13	47	71	155	94	1 - 2.5
ISSW323F	32A								92.5	166	105	2.5 - 6
ISSW164N	16A	Red 415V	3P + E						79	155	94	1 - 2.5
ISSW324N	32A								92.5	166	105	2.5 - 6
ISSW165N	16A		3P + N + E						79	155	94	1 - 2.5
ISSW325N	32A								92.5	166	105	2.5 - 6
ISSW163P	16A	Blue 230V	2P + E						71	155	94	1 - 2.5
ISSW323P	32A								92.5	166	105	2.5 - 6