

This document must be retained for future reference.

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation.  
All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS



Stainless Steel Enclosures

- Grade 304 Steel
- Brushed Stainless Steel Enclosure
- Earth studs and galvanised back plate included
- Stainless steel fixing brackets available



Dimensions

Part Number	External Dimension			Internal Depth	Mounting Plates		Other information (GPTN = Gland Plate Top & Bottom)
	H ( mm)	W (mm)	D (mm)		H2 (MM)	W2 (mm)	
SSTB302015	300	200	150	130	145	160	1 ▲ lock, No Glandplate
SSTB303015	300	300	150	130	245	250	1 ▲ lock, No Glandplate
SSTB403020	400	300	200	180	245	350	1 ▲ lock, No Glandplate
SSTB404020	400	400	200	180	345	350	1 ▲ lock, No Glandplate
SSTB504020	500	400	200	180	345	450	2 ▲ locks, No Glandplate
SSTB604020	600	400	200	180	340	540	2 ▲ locks, No Glandplate
SSTB606020	600	600	200	180	545	550	2 ▲ locks, No Glandplate
SSTB806020	800	600	200	180	545	745	2 ▲ locks, No Glandplate
SSTB806030	800	600	300	285	545	745	2 ▲ locks, No Glandplate
SSTB808030	800	800	300	285	745	745	2 ▲ locks, No Glandplate

