

This document must be retained for future reference.

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation. All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS




MEC2M|MEC3M|MEC4M|MEC6M IP40 Metal Clad Modular Enclosure with Metal Lid


- IP40 Enclosure
- Top and Bottom Knockouts
- Complete with Earth Terminal & Din Rai
- Epoxy powder coated RAL 7035
- Neutral Cable Sold Separately 16mm² X 230mm




MEC2M



MEC3M



MEC4M



MEC6M

