

This document must be retained for future reference.


It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation.
All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS



IP67 Interlocked Sockets (with key)



Part Number	No. of Poles	Current	Earth Pos.	Voltage	A	B	C	D	E	F
SISW163FF	2P+E	16A	4h	110V			130			
SISW163PF			6h	230V	90	180		184	79	169
SISW164VF	3P+E			400V			133			
SISW165VF	3P+N+E									

Part Number	No. of Poles	Current	Earth Pos.	Voltage	A	B	C	D	E	F
SISW323FF	2P+E	32A	4h	110V			146			
SISW323PF			6h	230V	90	180		190	79	169
SISW324VF	3P+E			400V						
SISW325VF	3P+N+E									