

This document must be retained for future reference.

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

All connections (including factory made) must be checked for the correct tightness prior to commissioning of the electrical installation. All connections should also be inspected periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS



RAS-BCBNO

Specifications and dimensions

- Contact block for 22mm devices
- Designed for use in plastic enclosures
- Normally open configuration



Features	
Length	30mm
Width	13mm
Depth	24mm
Weight	0.014Kg
Rated thermal current I _{th}	10A
Rated insulation voltage U _i	500V
Operating force	10N
Cable capacity	2 x 1.5mm ²
Contact operation	Slow action, positive opening
Related Products	
Normally closed contact	RAS-BCBNC

ⓘ ALL PRODUCTS, PRODUCT SPECIFICATIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE.

Information provided in data sheets and/or specifications may vary from actual results in different applications and performance may vary over time. **All products must be installed according to manufacturers instructions.**